Operator inspections

Gas extinguishing system · IG-541

SYSTEM	LOCATION	CALENDAR WEEK
Gaslöschanlage · BEISPIEL - FIKTIVE DATEN	Campus · Serverraum	38 / 2026

RESPONSIBLE PERSON	Max Muster	DEPUTY	Erika Beispiel

Active checkpoints according to the system configuration. Non-applicable items are not included.

Operator inspections in accordance with VdS 2240:2022-05 (06)

Weekly inspections

INSPECTION POINT	OK	NOT OK	N/A	DATE	VALUE / COMMENT
Fire detection equipment	X			17/09	
Extinguishing and control gas supply	X			17/09	
Extinguishing agent weight	X			17/09	
Operating position of valves	X			17/09	
Power supplies	X			17/09	

Date / signature of responsible operator

Deputy (if applicable)