Operator inspections

Water extinguishing system (sprinkler)

SYSTEM	LOCATION	CALENDAR WEEK
Sprinkleranlage · BEISPIEL - FIKTIVE DATEN	Campus · Technikgebäude	38 / 2026

RESPONSIBLE PERSON	Max Muster	DEPUTY	Erika Beispiel

Active checkpoints according to the system configuration. Non-applicable items are not included.

Operator inspections in accordance with VdS 2212:2015-03 (07)

Weekly inspections

INSPECTION POINT	OK	NOT OK	N/A	DATE	VALUE / COMMENT
Stop valves (operational position)	X			17/09	
Water level	X			17/09	
Alarm device	X			17/09	
Automatic pump start test	X			17/09	
Current consumption and mains changeover, if applicable	X			17/09	

Date / signature of responsible operator

Deputy (if applicable)